

Annual Drinking Water Quality Report Arnegard, North Dakota 2020

We're very pleased to provide you with this year's *Annual Drinking Water Quality Report*. We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is to provide you with a safe and dependable supply of drinking water. Our water source is surface water purchased from the city of Williston and distributed by McKenzie County Water Resource district. The city of Williston treats the water with filtration and lime softening. Chloramines are added for disinfection.

The City of Williston is participating in North Dakota's Wellhead Protection Program. Copies of the Wellhead Protection Program plan and other relevant information regarding this program can be obtained from the City Auditor during normal office hours. The North Dakota Department of Environmental Quality prepared a Source Water Assessment for Arnegard. Information on this program is available at the Auditor's office.

The city of Williston, in cooperation with the North Dakota Department of Environmental Quality, has completed the delineation and contaminant/land use inventory elements of the North Dakota Source Water Protection Program. Based on the information from these elements, The North Dakota Department of Environmental Quality has determined that our source water is "*moderately susceptible*" to potential contaminants. No significant sources of contamination have been identified.

This report shows our water quality and what it means. If you have any questions about this report or concerning your water utility, please contact Juelie Bancroft at 701-586-3453. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the 2nd Monday of every month in the Arnegard City Hall, starting at 7:00 PM. If you are aware of non-English speaking individuals who need help with the appropriate language translation, please call the number listed above.

The City of Arnegard would appreciate it if large volume water customers would please post copies of this *Annual Drinking Water Quality Report* in conspicuous locations or distribute them to tenants, residents, patients, students, and/or employees, so individuals who consume the water, but do not receive a water bill can learn about our water system.

The City of Arnegard routinely monitors for contaminants in your drinking water according to Federal and State laws. The following table shows the results of our monitoring for the period of January 1st to December 31st, 2020. As authorized and approved by EPA, the state has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of our data, though representative, is more than one year old.

The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land, or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water, industrial or domestic wastewater discharges, oil production, mining or farming.

Pesticides and herbicides, which come from a variety of sources such as agriculture, urban storm water runoff and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can, also, come from gas stations, urban storm water runoff and septic systems.

Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

To ensure that tap water is safe to drink, the Environmental Protection Agency (EPA) prescribes regulations which limit the number of certain contaminants in water provided by public water systems.

The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

In the following table, you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions.

Not applicable (NA), No Detect (ND)

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter ($\mu\text{g/l}$) - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/l) - Pico curies per liter is a measure of the radioactivity in water.

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

| 2020 Test results for the city of Arnegard, ND | | | | | | | | |
|---|-------------|------------|--------------------------------------|-------------------------|--------------|--------------------|--------------------------------------|--|
| <u>Contaminants</u> | <u>MCLG</u> | <u>MCL</u> | <u>Level Detected</u> | <u>Unit Measurement</u> | <u>Range</u> | <u>Date (year)</u> | <u>Violation Yes/No Other Info</u> | <u>Likely Source of Contamination</u> |
| Lead/Copper | | | | | | | | |
| Copper | 1.3 | AL=1.3 | 0.164 90 th % Value | ppm | N/A | 2020 | 0 Sites exceeded AL | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |
| Lead | 0 | AL=15 | 0.73 90 th % Value | ppb | N/A | 2020 | 0 Sites exceeded AL | Corrosion of household plumbing systems, erosion of natural deposits |
| Disinfectants | | | | | | | | |
| Chloramines | MRDLG =4 | MRDL =4.0 | 2.3 | ppm | 0-2.7 | 2020 | No | Water additive used to control microbes. |
| Stage 2 Disinfection By-Products (System-Wide) | | | | | | | | |
| HAA5 | N/A | 60 | 10 | ppb | N/A | 2020 | No | By-product of drinking water chlorination |
| TTHM | N/A | 80 | 23 | ppb | N/A | 2020 | No | By-product of drinking water chlorination |
| Microbiological Contaminants -Williston | | | | | | | | |
| Turbidity* | NA | TT | 0.17 | NTU | N/A | 2020 | 100% of samples met turbidity limits | Soil runoff |
| Inorganic Contaminants-Williston | | | | | | | | |
| BARIUM | 2 | 2 | 0.0143 | Ppm | NA | 2016 | No | Erosion of natural deposits, discharge of drilling wastes |
| CHROMIUM | 100 | 100 | 1.17 | Ppb | NA | 2016 | No | Discharge from steel and pulp mills: erosion of natural deposits |
| FLUORIDE | 4 | 4 | 0.81 | Ppm | NA | 2016 | No | Erosion of natural deposits, water additive which promotes strong teeth |
| Nitrate-Nitrite (as Nitrogen) | 10 | 10 | 0.106 | ppm | NA | 2020 | No | Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits |
| SELENIUM | 50 | 50 | 1.44 | ppb | NA | 2016 | No | Erosion of natural deposits, discharge from petroleum and metal refineries. |
| TOTAL ORGANIC CARBON REMOVAL (WILLISTON) | | | | | | | | |
| Alkalinity, Source-Williston | NA | NA | 174 | mg/l | 93.0-174.0 | 2020 | No | Natural erosion, certain plant activities, certain industrial wastewater discharges |
| Carbon, Total Organic (TOC) - Finished- Williston | NA | TT | 4.5 | MG/L | 2.20-4.50 | 2020 | No | Naturally present in the environment |

| | | | | | | | | |
|---|----|----|------|-------|------------|------|----|--|
| Carbon, Total Organic (TOC)- Source- Williston | NA | TT | 7.3 | MG/L | 3.00-7.30 | 2020 | No | Naturally present in the environment |
| Radioactive Contaminants- Williston | | | | | | | | |
| Gross Alpha, Including RA, Excluding RN and U | 15 | 15 | 3.9 | ppb | NA | 2017 | No | Erosion of natural deposits |
| Radium, Combined (226, 228) | NA | 5 | 0.78 | pCi/1 | NA | 2017 | No | Erosion of natural deposits |
| Uranium, Combined | NA | 30 | ND | ppb | -0.44 to 0 | 2017 | No | Erosion of natural deposits |
| Synthetic Organic Contaminants including Pesticides and Herbicides | | | | | | | | |
| Pentachlorophenol | 0 | 1 | 0.03 | ppb | NA | 2017 | No | Discharge from wood preserving factories |

Violation: Disinfectants and Disinfection Byproducts Rule (DBP) – Failure to Routine Monitor Chlorine (Major), 2nd quarter and 4th quarter of 2020. We failed to take the required number of samples for Chloramine during the 2nd quarter and 4th quarter of 2020. Some people who use water containing chloramines more than the MRDL could experience irritating effects to their eyes and nose. Some people who drink water containing chloramines more than the MRDL could experience stomach discomfort. The city of Arnegard is taking steps to correct this violation of the Disinfectants and Disinfection Byproduct Rule by returning to a normal testing routine.

Violation: Revised Total Coliform Rule (RTCR) – Failure to Routine Monitor May, November 2020. Our water system is required to sample for Total Coliform bacteria monthly. We failed to collect the required number of total coliform samples during the months of May, November 2020 and are therefore unsure of the quality of the water at that time. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. The city of Arnegard is taking steps to correct this violation of the Revised Total Coliform Rule by returning to a routine testing schedule. Subsequent total Coliform samples have been satisfactory.

Surface Water Treatment Rule Monitoring Data:

Lowest Monthly Percentage of Samples Meeting Turbidity Limits= 100

Highest Single Measurement = 0.17

*Turbidity is a measure of the cloudiness of the water. The city of Williston monitors it because it is a good indicator of the effectiveness of their filtration system. Turbidity is measured every four hours during treatment plant operations. 100% of samples met turbidity limits.

The City of Williston was selected by EPA to sample for unregulated contaminants during 2020. Samples for cyanotoxins were taken eight times at the entry point to the distribution system, as required. None of the unregulated contaminants being sampled were detected during the sampling events. Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant

monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted. Should you have any questions, please contact our office.

EPA requires monitoring of over 80 drinking water contaminants. Those contaminants listed in the table above are the only contaminants detected in your drinking water.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (1-800-426-4791]

MCL's are set at very stringent levels. To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

*If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Arnegard is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. **Use water from the cold tap for drinking and cooking. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking.** If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons, such as, persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Please call Juelie at 701-586-3453 if you have questions.

