


After Service Report

Cleaning & Disinfection Of Water Storage Tanks

Submitted to:

Global Indian International School



Senior Director

Dubai

AMOL VAIDYA

06 / 12 / 2021

Project Location:

GLOBAL INDIAN INTERNATIONAL SCHOOL

NEAR AL MANAMA HYPERMARKET

AL QUOZ - DUBAI, UAE




ANTONY KOSHY

Principal

06 / 12 / 2021

Dubai



**Water Storage Tank
Cleaning & Disinfection Certificate**

Customer Name: Global Indian International School	Issue Date: 25 Dec 2020
Contact Person: Ms. Sabeena James	Our Ref. No: CCFM/WTC/29/2020

Description and Location of Tank:

Water Tank Cleaning at: **Global Indian International School – Al Quoz, Dubai UAE**

Ground Level GRP: **1,500 gallons (2 nos.)**

Roof Top Molded Fiber Glass: **500 gallons (3 nos.)**

Date of Cleaning: **25 December 2020**

Frequency of Cleaning: **every six (6) months**

Date of Next Cleaning Due: **25 June 2021**


Additional Observations and Recommendations: *(See attached After Service Report)*

The procedures applied in this cleaning and disinfection complies with Dubai Municipality & Health and Safety Guidelines for Prevention of Legionella as well as BS6700 and City Care Facility Management LLC Method Statement.

The entire water storage tanks should be cleaned and disinfected every six (6) months depending upon condition.


On Behalf of City Care Facility Management LLC.


AMOL VAIDYA
Senior Director
Dubai
06 / 12 / 2021

Signed: 

Date: 10/01/2021

Stamp:




ANTONY KOSHY

Principal

06 / 12 / 2021

Dubai

Water Tank Cleaning & Disinfection After Service Report

Customer: Global Indian International School					
Address: Near Al Manama Hypermarket, Al Quoz, Dubai UAE					
Tel:		Mob: 0565064997		Contact Person: Ms. Sabrina	
Location of Tank: Ground Level (GRP) – 2 nos. Roof Top (Molded Fiber Glass) – 3 nos.			Ref No: CCFM/WTC/29/2020		Date: 25 DEC 2020
Type of Tank:					
☐ Concrete		☒ Molded Fiber Glass		☒ GRP Panel	
☐ Concrete Coated		☐ Galvanized		☐ Polyurethane	
				☐ Steel Panel	
				☐ Others	
Size of Tank: Ground Level (GRP) – 1,500 gallons (2 nos.) Roof Top (Molded Fiber Glass) – 500 gallons (3 nos.)					
Quantity of Water		☐ Full		☐ Half Full	
				☒ Empty	
Condition of Tank		☐ Clean		☒ Dirty	
				☐ Very Dirty	
Bio-Film/Staining		☐ Yes		☐ No	
				Sediment	
Mould		☐ Yes		☒ No	
				Algae	
Lid / Covers Fitted		☒ Yes		☐ No	
				☐ Damaged	
Leaks		☐ Yes		☒ No	
		Vent Screens Present		☐ Yes	
				☐ No	
				☒ N/A	
Vent Screens Installed		☐ Yes		☐ No	
				☒ N/A	
Pump Working		☒ Yes		☐ No	
				Valves Working	
Pipes		☐ Galvanized		☐ UPVC	
		☐ Copper		☒ Yes	
				☐ No	
				Tank Fitted with a Drain	
				☒ Yes	
				☐ No	
Access:					
Ladder Inside		☐ Yes		☐ No	
				Ladder Outside	
				☐ Yes	
				☒ No	
Last Cleaned:		Current Date of Cleaning: 25-DEC-2020		Team: Zohaib	
				Next Date of Cleaning: 25-JUN-2021	
Pipes Disinfected		☐ Yes		☒ No	
				☐ N/A	
Test Method		Result		Discharge	
				Correction Method	
☐ 1		☒ 2		☐ Yes	
				☐ No	
☐ 1		☐ 2		☐ Yes	
				☐ No	
☐ 1		☐ 2		☐ Yes	
				☐ No	
☐ 1		☐ 2		☐ Yes	
				☐ No	
				☐ A	
				☐ B	
				☐ A	
				☐ B	
				☐ A	
				☐ B	
LEGEND:		1 = Litmus Paper		2 = pH Test Kit	
				3 = Photometer	
				A = Dilute with water	
				B = Add Neutralizer	
Signed on Behalf of City Care Facility Management LLC.					
Comments:					

ANTONY KOSHY


Principal
06 / 12 / 2021
Dubai

AMOL VAIDYA
Senior Director
Dubai
06 / 12 / 2021

Principal
Global Indian International School
LLC
Dubai, UAE



ROOF TOP LEVEL WATER TANK



AMOL VAIDYA

Senior Director
Dubai

06 / 12 / 2021



ANTONY KOSHY


Principal

06 / 12 / 2021

Dubai



TANK 1



BEFORE SERVICE

AVaidya

AMOL VAIDYA

Senior Director
Dubai

06 / 12 / 2021

AK

ANTONY KOSHY

Principal

06 / 12 / 2021

Dubai




AFTER SERVICE



TANK 2



BEFORE SERVICE



AFTER SERVICE

ANTONY KOSHY

Principal

06 / 12 / 2021

Dubai


AMOL VAIDYA

Senior Director
Dubai
06 / 12 / 2021


Principal
Global Indian International School
LLC
Dubai, UAE



TANK 3



BEFORE SERVICE



AFTER SERVICE


Principal
Global Indian International School
LLC
Dubai, UAE


ANTONY KOSHY

Principal

06 / 12 / 2021

Dubai


Senior Director

Dubai

06 / 12 / 2021

AMOL VAIDYA



GROUND LEVEL WATER TANK




ANTONY KOSHY

Principal

06 / 12 / 2021

Dubai



AMOL VAIDYA


Senior Director
Dubai

06 / 12 / 2021

TANK 1



BEFORE SERVICE




AFTER SERVICE


ANTONY KOSHY

Principal

06 / 12 / 2021

Dubai


AMOL VAIDYA

Senior Director
Dubai

06 / 12 / 2021


Principal
Global Indian International School
LLC
Dubai, UAE



TANK 2



BEFORE SERVICE




AFTER SERVICE


ANTONY KOSHY

Principal

06 / 12 / 2021

Dubai


AMOL VAIDYA

Senior Director
Dubai
06 / 12 / 2021


Principal
Global Indian International School
LLC
Dubai, UAE



TEST REPORT FOR MICROBIOLOGICAL ANALYSIS

CUSTOMER INFORMATION			
Customer Name: City Care Facility Management LLC			
Address: P.O. Box No. 32854, Dubai, UAE			
Tel: 04 3373535 Fax: 04 3377969			
SAMPLE INFORMATION			
Report no.	M/6773/1	Sampling Plan	Contract
Sample no.	6773/1	Sampling Date/Time	28/12/20, 11:40AM
Job no.	8534	Sample received on	28/12/20, 4:00PM
Sample Name	Water - Potable	Sampled by	RTL Rep.
Sample point	Ground Floor Domestic Water Tank	Sample received temp. on site/lab	27.5°C / 8.1°C
Sample method	APHA 9060A, 23 rd Ed. 2017	Sample condition	Satisfactory
Source of sample	Global Indian International School	Physical Appearance	-
Test dates	28/12/20 - 02/01/21	Reference (if any)	-
Reporting date	02/01/21	Tested by	RTB
		Authorized recipient	Engr. Irfan Ahmed

ANTONY KOSHY

Principal

06 / 12 / 2021

Dubai

S.No	Parameters	Test Methods	Units	Results	*Limits
1.	Total Plate Count	APHA 9215B; 23 rd Ed. 2017	CFU/ml	39 x 10 ¹	500/ml
2.	E.coli	APHA 9222J; 23 rd Ed. 2017	CFU/100ml	Not Detected	Absent/100ml
3.	Total Coliforms	APHA 9222J; 23 rd Ed. 2017	CFU/100ml	Not Detected	Absent/100ml
4.	Pseudomonas aeruginosa	ISO 16266:2006E	CFU/100ml	Not Detected	Absent/100ml

Remarks: The sample analyzed is of satisfactory quality with respect to above tested parameters.

Test Method Variation: None.

*Limits: National primary drinking water regulation EPA 816-F-09-004, May 2009, US Environmental Protection Agency.

SOP No: RTL/MIC/SOP: 01, 02 & 12

Key Words: CFU - Colony Forming Units, APHA - American Public Health Association, . ISO - International Organization for Standardization

The results stated in this report refer only to the samples tested and shall only be reproduced in full and with the written approval of RTL Laboratory.

[Signature]
for Authorized by TM

Senior Director
Dubai

06 / 12 / 2021

AMOL VAIDYA

[Signature]
Principal
Global Indian International School
LLC
Dubai, UAE



elac
Emirates International Accreditation Centre
125-LB-TEST

Reliable Testing Laboratory L.L.C
P.O.Box : 211714, Jebel Ali Ind. Area No: 01, Dubai, U.A.E
Tel : +971 4 885 2022 | Fax : +971 4 885 2033
Email : info@rtlab-intl.com | Website : www.rtlab-intl.com

TEST REPORT FOR LEGIONELLA ANALYSIS

CUSTOMER INFORMATION			
Customer Name: City Care Facility Management LLC			
Address: P.O. Box No. 32854, Dubai, UAE			
Tel: 04 3373535 Fax: 04 3377969			
SAMPLE INFORMATION			
Report no.	M/6773/1	Sampling Plan	Contract
Sample no.	6773/1	Sampling Date/Time	28/12/20, 11:40AM
Job no.	8534	Sample received on	28/12/20, 4:00PM
Sample Name	Water - Potable	Sampled by	RTL Rep.
Sample point	Ground Floor Domestic Water Tank	Sample received temp. on site/lab	27.5°C / 8.1°C
Sample method	BS 7592; 2008	Sample condition	Satisfactory
Source of sample	Global Indian International School	Reference (if any)	-
Neutralizer used	1ml of 3% Na ₂ S ₂ O ₃	Maximum volume test	1000ml
Test dates	28/12/20 - 07/01/21	Tested by	RTB
Reporting date	07/01/21	Authorized recipient	Engr. Irfan Ahmed

S.No	Parameters	Test Methods	Units	Results	*Limits
1.	Legionella sp.	ISO 11731:2017	CFU/liter	<1	1000/liter
2.	Legionella pneumophila Serotype 1	ISO 11731:2017	CFU/liter	<1	1000/liter
3.	Legionella pneumophila Serotype 2- 14	ISO 11731:2017	CFU/liter	<1	1000/liter

Remarks: The sample analyzed is of satisfactory quality with respect to above tested parameters.

Test Method Variation: None

Note: <1 is equal to Not Detected.

*Limits: DM Guidelines for control of legionella in water System, Rev: 2.

SOP No: RTL/MIC/SOP: 11, Matrix: A, Test Procedure: 7 (Acid Treatment) Media Used: BCYE+GVPC

Key Words: CFU- Colony Forming Units, ISO-International Organization for Standardization.

The results stated in this report refer only to the samples tested and shall only be reproduced in full and with the written approval of RT Laboratory.

[Signature]
Authorized by TM

[Signature]
Principal
Global Indian International School
LLC
Dubai, UAE



ANTONY KOSHY

Principal

06 / 12 / 2021

Dubai

[Signature]

Senior Director
Dubai

AMOL VAIDYA

06 / 12 / 2021



Reliable Testing Laboratory L.L.C
P.O.Box : 211714, Jebel Ali Ind. Area No: 01, Dubai, U.A.E
Tel : +971 4 885 2022 | Fax : +971 4 885 2033

Email : info@rtlab-intl.com | Website : www.rtlab-intl.com

Public Health & Safety Department

Consumer Products Safety Section

Consumer Products Registration Certificate

Biocides

إدارة الصحة والسلامة

قسم سلامة المواد الاستهلاكية

شهادة تسجيل مواد استهلاكية

مضادات الجراثيم

Reference Number:	CPRE-2020-039021	رقم المرجع :
Registration Status:	Approved	حالة التسجيل :
Registration Date:	13/09/2020	تاريخ التسجيل :
Category:	B2B Products	صنف المنتج :
Brand Name:	ELEGANT	العلامة التجارية :
Company Name:	EPOCH AEROSOLS INDUSTRIES LLC	اسم الشركة :
Country of Origin:	United Arab Emirates	البلد المنشأ :

Product Details	تفاصيل المنتج
Product Name	
ULTRA HYGIENIC Hand Sanitizer Gel	

Important Notes

ملاحظات هامة

- Registration Certificate is valid for 5 years from date of issue & any alteration or deletion in any way will invalid it.
- Registration Certificate is granted upon company's request and the above listed product is freely distributed in the local market & Dubai Municipality will not be responsible for any consequences of variations in the product.
- Registration Certificate is issued upon the currently enforced regulations and subjected for modification according to the requirements of concerned department.
- All the imported & marketed products will be subjected to inspection and conformity with the currently enforced regulations

- شهادة التسجيل صالحة لمدة 5 سنوات من تاريخ إصدارها وأي تغيير أو شطب يلغيها
- تم إصدار شهادة التسجيل بناء على طلب الشركة والمنتج المذكور أعلاه مسموح تداوله في الأسواق المحلية، ولا تتحمل البلدية أية مسؤولية في حال حدوث أية تغييرات في المنتج
- تم إصدار شهادة التسجيل حسب الانظمة القائمة حالياً وتكون قابلة للتعديل حسب متطلبات الإدارة المختصة والأنظمة المعمول بها في حينه
- كل المنتجات المستوردة أو المتداولة سوف تخضع للتفتيش و المطابقة وحسب الأنظمة المعمول بها في حينه.

This certificate has been electronically generated and approved by Dubai Municipality and does not need signature or Stamp .

هذه الشهادة صادرة و معتمدة الكترونياً من بلدية دبي و ليست بحاجة إلى توقيع أو ختم

Consumer Products Safety Section

قسم سلامة المواد الاستهلاكية

06 / 12 / 2021

Dubai



Senior Director
Dubai
06 / 12 / 2021

AMOL VAIDYA

Our Vision: Creating an excellent city that provides the essence of success and comfort of sustainable living.

ص.ب: 67 دبي , إ.ع.م. هاتف: +97142215555, فاكس: +97142246666

P.O.Box: 67 DUBAI, UAE, Tel.: +971 4 221 5555, Fax.: +971 4 224 6666
E-mail: info@dm.gov.ae Website: www.dm.gov.ae


Doc ID: 609a18e1cdeaff482a114d5c3eb90ae1b114b6c6

Variants Information

ULTRA HYGIENIC
Hand Sanitizer
Gel

International Barcode:	3571700502806	Scent / Flavor:	Fresh
Product Color / Shade:	Colorless	Size / Weight / Volume:	5 L


ANTONY KOSHY
Principal
06 / 12 / 2021
Dubai


AMOL VAIDYA
Senior Director
Dubai
06 / 12 / 2021


Principal
Global Indian International School
LLC
Dubai, UAE



Public Health & Safety Department
Consumer Products Safety Section

إدارة الصحة و السلامة
قسم سلامة المواد الاستهلاكية

Consumer Products Registration Certificate

شهادة تسجيل مواد استهلاكية

Biocides

مضادات الجراثيم

Reference Number:	CPRE-2020-011634	رقم المرجع :
Registration Status:	Approved	حالة التسجيل :
Registration Date:	16/03/2020	تاريخ التسجيل :
Category:	B2B Products	صنف المنتج :
Brand Name:	NADES	العلامة التجارية :
Company Name:		اسم الشركة :
Country of Origin:	United Arab Emirates	البلد المنشأ :

Product Details تفاصيل المنتج
Product Name
NADES - Super Oxidized Disinfectant Solution

Important Notes

ملاحظات هامة

- Registration Certificate is valid for 5 years from date of issue & any alteration or deletion in any way will invalid it.
- Registration Certificate is granted upon company's request and the above listed product is freely distributed in the local market & Dubai Municipality will not be responsible for any consequences of variations in the product.
- Registration Certificate is issued upon the currently enforced regulations and subjected for modification according to the requirements of concerned department.
- All the imported & marketed products will be subjected to inspection and conformity with the currently enforced regulations
- This certificate has been electronically generated and approved by Dubai Municipality and does not need signature or Stamp.

- شهادة التسجيل صالحة لمدة 5 سنوات من تاريخ إصدارها وأي تغيير أو شطب يلغيها
- تم إصدار شهادة التسجيل بناء على طلب الشركة والمنتج المذكور أعلاه مسموح تداوله في السواق المحلية، ولا تتحمل البلدية أية مسؤولية في حال حدوث أية تغييرات في المنتج
- تم إصدار شهادة التسجيل حسب الانظمة القائمة حاليا وتكون قابلة للتعديل حسب متطلبات الإدارة المختصة والأنظمة المعمول بها في حينه
- كل المنتجات المستوردة أو المتداولة سوف تخضع للتفتيش و المطابقة وحسب الأنظمة المعمول بها في حينه
- هذه الشهادة صادرة و معتمدة الكترونيا من بلدية دبي و ليس بحاجة إلى توقيع أو ختم

Consumer Products Safety Section

قسم سلامة المواد الاستهلاكية

ANTONY KOSHY

Principal

06 / 12 / 2021

Dubai

AMOL VAIDYA

Senior Director
Dubai

06 / 12 / 2021

Our Vision: Creating an excellent city that provides the essence of success and comfort of sustainable living
رؤيتنا: بناء مدينة متميزة تتوفر فيها استدامة رفاحية العيش و مقومات النجاح

ص.ب: 67 دبي، ا.ع.م. هاتف: +97142215555، فاكس: +97142246666

P.O.Box: 67 DUBAI, UAE, Tel.: +971 4 221 5555, Fax.: +971 4 224 6666


E-mail: info@dm.gov.ae Website: www.dm.gov.ae

Doc ID: 669a18e1cdeaff482a114d5c3eb90ae1b114b6c6

Variants Information

NADES Super
Oxidized
Disinfectant
Solution

International Barcode:		Scent / Flavor:	Slight Chlorine Smell
Product Color / Shade:	CLEAR	Size / Weight / Volume:	25 L


AMOL VAIDYA

Senior Director
Dubai
06 / 12 / 2021


Principal
Global Indian International School
LLC
Dubai, UAE


ANTONY KOSHY
Principal
06 / 12 / 2021
Dubai



Cleaning and disinfection report

ANTONY KOSHY

Principal

06 / 12 / 2021

Dubai

AMOL VAIDYA

Senior Director
Dubai
06 / 12 / 2021

Global Indian International School
Principal
LLC
Dubai, UAE



Site details (Name, Location, Trade License etc.)	Global Indian International School LLC in Al Meydan Road, Al Quoz – 1 Grade-5
Service request receipt date and time	36445, 29/4/2021 & 7:30 PM
Response date and time	01/05/2021 & 3:00 PM
Disinfection process start and end time	01/05/2021 & 03:00PM TO 03:30 PM
Disinfected facilities onsite	Global Indian International School LLC in Al Meydan Road, Al Quoz – 1 Grade-5
Total manpower involved	2
Materials used for disinfection	Disinfectant: CulliganSafe Guard 45H25 Equipment Used: ULV Fogging machine
Total hazardous waste generated (Amount in Kg)	2 kg
Hazardous waste disposal (Method, Date and Time, Site, Transporter ... etc.)	1. Discard PPE2. Put discarded PPE inside the Medical biohazards infectious waste Disposal Bag.3. Disinfect the bag.4. Bring the Bag to the warehouse where it will be disposed inside a special bin from which waste management company will take.
Precautionary measures for (Manpower involved, Residents onsite etc.)	Disinfectant Team: Trained to use the product and all needed PPE (Overall, Mask, Gloves, etc.)
Standard adopted for disinfection process	Dubai Municipality / Product Standards
Description of the disinfection process	1 misting the whole area of the premises in the office 2. Spray hard surfaces with Medical grade disinfectant.

Cleaning and disinfection report

ANTONY KOSHY
Principal
06 / 12 / 2021
Dubai

AMOL VAIDYA
Senior Director
Dubai
06 / 12 / 2021



License Number:

105918



Company Name: Jumeira Pest Control

Manager Signature:

Company Stamp:

