

ETK-HT, SPK-HT

HT Series End Termination and Splice Kits

ETK-HT



DESCRIPTION

The ETK-HT Silicone End Cap Component is used when making one end termination on HT Series cable.

CONTENTS

A. 1 Silicone End Cap

ITEMS REQUIRED BUT NOT SUPPLIED

- High Temperature Fiberglass Tape (T-F50H)
- Silicone Sealant (included in ETK-HT5)

TOOLS REQUIRED


- Lineman's Pliers
- Utility Knife

TERMINATING THE CABLE

CAUTION: Do not connect Bus Wires.

See ETK-HT High Temperature (HT) Series Termination Kit Installation Instructions.

SPK-HT-1



DESCRIPTION

The SPK-HT components** allow you to make 1 or 5 splices (depending on the kit) on HT Series cables.

SPK-HT-1 (for 1 splice) includes:

- A. 4 on-Insulated Butt Compression Splices
- B. 1 roll of High Temperature Fiberglass Tape
- C. 1 tube of Silicone sealant*

*California Prop 65 compliant.

** From FM approved kit.

SPK-HT-5 includes enough for 5 splices

TOOLS REQUIRED

- Lineman's Pliers
- Utility Knife



WARNING: The ETK-HT5 kit and the cable used with it must be installed by a qualified electrician. All assembly, installation and test instructions must be followed. Improper installation can result in property damage, serious injury, and/or death due to electric shock and fires. Please call Delta-Therm Corporation at 800-526-7887 with any installation or operating questions.