



Round Valley Agency Annual Water Quality Report

Public Water System #0905073

2014

Is my water safe?

This report is a snapshot of your water quality. Included are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The Environmental Protection Agency (EPA) and Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Your water comes from 1 ground water source.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity including: *microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.*

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public

| | | | | | | | | | |
|----------------------------------|-----|-----|--------|------|-----|---|----|--|------------------------------|
| Sodium | 12 | N/A | N/A | 2014 | N/A | Erosion of natural deposits; salt water intrusion | | | |
| Units: ppm | | | | | | | | | |
| Lead and Copper Rule | | | | | | | | | |
| Copper | 1.3 | 1.3 | 0.29 | N/A | N/A | 2013 | No | Corrosion of household plumbing systems; erosion from wood preservatives | of natural deposit; leaching |
| Units: ppm - 90th Percentile | | | | | | | | | |
| Radiological Contaminants | | | | | | | | | |
| Adjusted Alpha (Excl. Radon & U) | 0 | 15 | 0.95 | N/A | N/A | 2011 | No | Erosion of natural deposits | |
| Units: pCi/L | | | | | | | | | |
| Combined Radium 226/228 | 0 | 5 | 1.59 | N/A | N/A | 2011 | No | Erosion of natural deposits | |
| Units: pCi/L | | | | | | | | | |
| Uranium (combined) | 0 | 30 | 1.4155 | N/A | N/A | 2011 | No | Erosion of natural deposits | |
| Units: ppb | | | | | | | | | |

Special Education Statements

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. PWS system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at 1-800-426-4791 or at <http://www.epa.gov/safewater/lead/leadfactsheet.html>.

Unit Descriptions

| Term | Definition |
|-------------------|---|
| ppm | ppm: parts per million, or milligrams per liter (mg/L) |
| ppb | ppb: parts per billion, or microgram per liter (ug/L) |
| positives samples | positive samples/yr: the number of positive samples taken that year |

| | |
|--------------------------|---|
| % positive samples/month | % positive samples/month: % of samples taken monthly that were positive |
| N/A | N/A: Not applicable |
| ND | ND Not detected |
| NR | NR: Monitoring not required, but recommended. |
| MCLG | MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. |
| MCL | MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. |
| TT | TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water. |
| AL | AL: Action Level: The concentration of a contaminant which, if exceeded, trigger treatment or other requirements which a water system must follow. |
| Variances and Exemptions | Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions. |
| MRDLG | MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants. |
| MRDL | MRDL: Maximum residual disinfectant level. The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants. |
| MNR | MNR: Monitored Not Regulated |
| MPL | MPL: State Assigned Maximum Permissible Level |
| mrem/yr | mrem/yr: Millirem per year |

Monitoring and Reporting Violations

| Contaminant Name Rule | Type of Violation | Begin/End Date | Comment | Steps Taken to Correct the Violation | Return to Compliance | Return Date | Action Comment |
|--------------------------|-------------------------------|-------------------------|----------------------|--|-------------------------|----------------|---------------------|
| Total Coliform | Major monitoring/reporting | 11/1/2014 11/30/2014 | No routines reported | Report all future required results. | Yes | 2/20/2015 | Sampled 12/15/14 |

violation for routine
bacteriological
monitoring.

How can I get involved?

If you want to be involved and participate in the operation and maintenance of your water quality, please consider joining the Tribes Utility Board. Write a letter of intent to Tribal Council at 77826 Covelo Road, Covelo CA, 95428. If you have any questions and/or comments, please feel free to contact the number provided below for more information. Your input is important to us!

For more information please contact:

Justin Britton, Water Association Lead Operator, 77826 Covelo Road, Covelo, California 95428-9552

Phone: (707) 983-8204

Fax: (707) 983-6128